



CONFORMITY CERTIFICATE OF EXPLOSION-PROOF

Certificate No.: CCRI 25.2649X

Applicant Company: FTI TECHNOLOGY INC.

Address: 1013 Centre Road, Suite 403S Wilmington, DE 19805 USA

Name of Product: differential pressure transmitter

Type of Product: PB430Series

Marking: Ex ia II C T4 Ga

Technical Documents: Q/FTI 002-2025

Drawing No.: PB430-000

Note(s):

1. Rated voltage: 24VDC, use an associated device that matches its intrinsic safety parameters.
Intrinsic safety parameters: U_i :DC28V, I_i :93mA, P_i :0.65W, C_i :10nF, L_i :0mH.
2. IP code: IP67.
3. The certificate suffix "X" indicates that the device is used in Zone 0 and should be protected from ignition hazards caused by impact or friction.
4. Association inspection report number: 2025550340.

By verifying the drawings and technical documents and checking samples, the product complies with the following standards currently valid in P.R.China:

GB/T 3836.1-2021, GB/T 3836.4-2021, GB/T 4208-2017

Date of Issue: 5. 19. 2025

Valid till: 5. 18. 2030

Authorize:



CCRI (Beijing) Testing Technology Co., Ltd.

(Beijing Test Center of Mine Working Equipment and Mining Oils for National Safe Production)

Note: This certificate is only valid for the products that are in accord with samples tested and verified.

Address: Building 6, No.5, Yulong Street, Caiyu Town, Beijing Economic and Technological Development Area(Daxing), Beijing Tel/fax: 010-89268018

The query url of Explosion-proof Certificate: <http://jc.ccrtec.com.cn>